

FACILITIES and PARKS STATUS

February 20, 2017

- Interviews were done for the new maintenance worker position. 8 applicants were interviewed.
- A water leak on the 2nd floor of the Municipal Building caused heavy damage throughout the 1 floor and the basement. Contractors have been on site and we are working with our insurance company to cover costs.
- New sound proofing boards were installed in the interview room at the Police Station.
- The parks department (believe it or not) has ordered the spring annuals to be delivered in a couple of months to grow in our greenhouse. Spring is right around the corner.
- Engineering has begun at the Municipal Building for the upgrades to the HVAC systems. Physical work to begin in the next couple of weeks.
- Parks Department is working in shop on park benches and picnic tables. Work includes painting and staining.
- Spring preventative maintenance has begun on heating and cooling systems throughout the City. The Municipal Building, Town Hall and the Golf Course are complete.
- We met with GPM art department on installing a mural on the front of Kids Space. The mural will be dedicated on Arbor Day.
- Tree City application has been accepted. The TC luncheon will be held in Grove City on April 19th.
- The Parks Department is gearing up for the snow removal season, the Department has been out several times this year and the team is doing a great job.

- Water samples have been taken from the Rec Center to see if electrolysis is an issue within the water lines.
- Repairs were made to a roof unit at the golf course. The unit supplied heating and cooling to the restaurant area.
- The roof unit supplying heating to the building department had a stuck damper and was supplying cold outside air to the department. The damper has been fixed.